

**B2 - CD With Current Storm Water
System and Watershed Layer**

B3 - Citizen Complaint Database

2. J
Citizen Complaint Database

Date	Address	Name	Complaint	Corrective Action
03/04/15	4100 Hillcrest Ave	Did not leave	Storm inlet at driveway is clogged up and holding water	Cleaned 3/9/15
03/04/15	1106 Greer St	Gloria Pounds	Alley drainage wants ditches in alley	No ditches in alley, topography does not allow ditches
03/04/15	2337 Jefferson St	Donald Overstreet	Alley Drainage	Alley meeting with RM and neighbors
03/10/15	2517 Alabama St	Betty Newton	Large tree on top of bank of ditch needs to be removed	Removed tree.
03/12/15	309 Vermont St	Jeff Dalton	Wants new driveway pipe	Upon inspection pipe was fine and adequately sized
04/01/15	268 N 36th St	Peyton Jones	Roadside drainage and pool install	Pipes were installed
04/02/15	2749 Clay Street	Rose Hughes	Inlet clogged in Joe Clifton	KYTC issue - contacted them
04/06/15	2212 Jefferson St	Allen Bright	Alley and front yard drainage	Alley meeting with RM and neighbors
04/06/15	2216 Jefferson St	Neil Scott	Alley drainage backing up into his garage	Alley meeting with RM and neighbors
04/07/15	118 Iroquois Drive	David Emerson	Ditch eroding and not draining like it used to	Ditch ok
04/07/15	246 Seminole Dr	Joby Hart	Private property drainage issue with neighbor	NA
04/08/15	2807 Norton	Betty Peeler	Ditch in front yard not draining	Owner needs to maintain driveway culvert (clean up leaves) but we will dig out ditch where sediment collected
04/12/15	3040 Monroe St	Dorothy Golightly	Alley drainage	Modify alley layout
04/13/15	1914 Washington St	Betty Bearden	Alley drainage	COP re-ditched alley
04/14/15	925 Park Ave	Paul Berger	Alley driveway pipe crushed	COP replaced 20' of 12" RCP
04/15/15	1815 N 10th St	Jean Reineking	Alley drainage	No ditches in alley, topography does not allow ditches
04/21/15	215 Kennedy Rd	Pat Hayes	Driveway pipe needs replaced, sinkhole in sideyard	Kennedy road pipe replacement, PROJECT
04/21/15	1119 Friedman Lane	Ann King	Front yard swale not draining	City re-graded to remove high spot in ditch
04/21/15	1701 Bloom Ave	Warren Pendleton	Concrete retaining wall on each side of driveway	Met with owner and told him he could perform the work but I would need to inspect before he poured the walls
04/27/15	3200 Monroe Street	William Humprey	Alley drainage issue	City re-ditched to remove sediment buildup
04/27/15	1901 Clark St	Josh Taber	Alley drainage issue	City re-ditched through new driveway that was installed at duplex
04/27/15	3210 Schneiderman RD	Larissa Munsell	Alley drainage	Ditches not needed
04/30/15	1801 N Friendship Rd	Gladys Morgan	Drainage in side and front yard	met with PO and told her she needed to install a french drain to help with her yard issues - no WO needed
05/01/15	2955 Alabama St	Heather Gubbs	Need driveway pipe	Needs a driveway with swale, no cover for pipe
05/04/15	4100 Phillips Ave	Phyllis Curtis	Driveway pipe needs replaced, cleared obstruction (large piece of wood) at 4040 Minnich Ave driveway	Clear the obstruction at the downstream culvert
05/04/15	2416 Barnette St	Todd Knuckles	Ditch eroding	It is natural, need to leave some vegetation to keep erosion from occurring. Told PO he can maintain but do not burn all vegetation off.
05/04/15	1030 N 12th St	James Dabney	Wants to install drive off alley	No pipe needed
05/11/15	2303 Seneca Lane	Jan Keen	Driveway culvert crushed	fixed by COP
05/12/15	3415 Jefferson St	NA	Cut tree down	Tree was cut

Citizen Complaint Database

05/14/15	400 N 36th St	Lynn Bundy	Sidewalk holds water	Spoke to PO and performed survey. COP will cut two trees in ROW that is damaging the sidewalk and replace sidewalk at a shared cost of 50% with PO according to RM. The sidewalk shall be raised 6" at the end and pivot from second driveway.
05/25/15	2550 Laclede Ave		Alley drainage	Alley does not have an outlet, digging ditches will make a ponding effect because it will be lower than the outlet
05/26/15	2553 Harrison St		Alley drainage	Alley does not have an outlet, digging ditches will make a ponding effect because it will be lower than the outlet
05/28/15	2909 Mississippi St		Grates missing on trench drains in ROW	COP installed new ones
06/22/15	1630 Bloom Ave	Roger Davenport	Wants to install pipe in alley	Gravel drive does not need pipe, not enough cover for 12" minimum
07/06/15	1900 Hendricks St	Dwain Norsworthy	Sinkhole	Told Powner to have JSA inspect because it was in vicinity of the lateral line
07/06/15	1027 S 5th St		Corner lot holds water near Street in ROW	Do not trench to C&G because it may cause traffic safety issues with flooding gutter spread, spoke to owner
07/06/15	118 Nolan Drive	Charles Hayden	Driveway at ROW is caving in	No issue, not City's problem
07/06/15	2540 Madison St	Beth Ray	Inlet behind alley may be clogged with debris	Inlet was clean, only 8" pipe
07/07/15	2710 Legends	David Carr	Mud coming off Chandler Park Apartment Development	Contractor is cleaning it up and addressing the issue
07/07/15	23rd and 24th Monroe & Madison Streets		Flooding in alley	5-4" rain in 2.5 hours. System was inundated with water. Home flooded.
07/07/15	1101 Harrison St	Sue Green	Inlet in front of 1100 is holding water needs to be pumped out	
07/07/15	2304 Beiderman	Christine Davis	Inlet is blocked	Contacted Brandy to have cleaned
07/10/15	700 Woodland Dr	Allen Robinson	CB washing out on corner of property	Spoke to Brandy and she said they would repair once pump truck was fixed. Relayed this message to the owners.
07/10/15	726 N 26th St	Larry Haley	Sinkhole in street	Brandy to complete fix
07/10/15	600 N Valley Rd	Jack Johnson	Gravel from alley washing into his yard	Scaup alley, plant grass
07/10/15	1106 Greer St	Gloria Pounds	Alley needs to be ditched, holding water	Site visit with RM
07/15/15	2011 S 28th St	William Morris	Roadside ditch is holding water	Ditch needs to be re-ditched DS of 2011 to relieve the standing water. Re-ditch and clean culverts from 2019 to 2035 S 28th St. Culvert at 2019 is where the water is holding down to 2011.
07/15/15	926 Stonebrook Dr	Jennifer Rukavina	Worried about french drain adjacent property owner installed.	I told her that it is a private property issue but shall not adversely effect her property because the french drain outlets into the street which ultimately drains to a pond.
07/17/15	2401 S 28th St	Peggy Keith	Flooding	Ditch behind home and inlet to be cleaned

Citizen Complaint Database

07/17/15	1640 Washington St	Darla Simmons	Storm drain on property, wanted info on it	Spoke to PO, explained to her the rarity of the storm event we had on 7/7 and that she lives in a low spot. Directed her to Josh Webb of JSA because the 10" VCP on her property connects into a combined sewer.
07/21/15	2733 S 28th St	Billy Hooks	Drainage ditch washed out driveway	Discuss with RM, per RM if the City installed the driveway culvert then the City would repair it. I spoke to property owner and she said her husband put the pipe in several years ago. Therefore, the City will not fix the driveway.
07/21/15	3234 River Oak Blvd	Sue Phillips	Ditch washed out	Repair the culvert that is washed out, pipe looked to be ok and re-usable just fix wash out area - discuss with RM. Per RM remove the pipe and dress up the ditch. We do not use this as a road.
07/21/15	Walter Jetton Blvd & Bronson Ave		stopped up storm drain	Clear inlets of debris
07/21/15	2629 Adams St	Louise Gulling	Alley needs to be re-ditched	Regrade alley ditches and remove obstructions
07/22/15	2890 Broadway	Jeff Modglin	Storm drain concerns at First Baptist Church	Not COP issue, private property issue
07/22/15	1403 Monroe St	Megan Croft	Drains near house stopped up	Inspected drains and they were free of obstructions, relayed message to owner
07/23/15	2525 Irvin Cobb Dr	Liz Walker	Responsible for keeping ditch clean?	We have a 15' esmt on ditch, need to clean and maintain culvert was in great shape, not collapsed and no obstructions, left message on PO's voice
07/23/15	329 Friedman Ave	Lisa Chappell	Driveway culvert collapsed	
07/23/15	3217 Jefferson St	Jim Anderson	concerned of the stoop PO behind him built in the alley RR causing drainage issue with gravel they put in RR ROW	Spoke to PO at Jefferson and 3208 Monroe. Told the PO who built the stoop that we would be removing it because it was in the ROW and blocking drainage. Her only concern was for us to leave the rock of which we did.
07/23/15	700 N 34th St	Doyott White	alley ditches are clogged and obstructed	Not COP issue, need to make complaint to the RR
07/23/15	2200 Harrison St	Jim Ricks	Neighbor has done trench work and making sure it will not cause him drainage issue	Regard alley ditches and clear obstructions
07/28/15	3200 Jefferson St	Ron Curry	Wants to extend driveway and new culvert	Drainage has always gone there, PO was cleaning up unimproved alley ditch, site visit with RM
07/30/15	2230 Olympia Ave	Jack Boyster	Wants ditches graded in front of business because he flooded during the 7/7/15 storm event	Price given on 24' of 12" RCP
08/04/15	200 S 31st St	Charles Jackson	Flooded from the 7/7/15 event and didn't know if pipe was size appropriately	Ditches do not need to be regraded, told PO that he may want to modify his roof drains to prevent water from standing at foundation but the ditch had good fall/vegetation/no obstructions in it. See file for pictures
08/04/15	836 Whitney Avenue	Jeff See	Driveway pipe clogged	Made site visit, new home that is a walkout. The walkout is level or below top of bank of creek. When creek floods it will head strait for the walk out basement. Pipe sized for 10 yr storm not the event we had on 7/7/15.
07/14/15	2805 Washington St	Kevin McCauley		Site visit with RM, Per RM culvert not needed. This would be a serious drainage project and we are not going to do it at this time.

Citizen Complaint Database

08/17/15	1951 Monroe St	Melody Lecornu		Adding rock in alley, drainage issue in backyard	Did not add rock in alley, explained to her that it is all about topo and that there is not much we can do for low areas such as her yard. Gave her advice on french drain.
08/17/15	653 N 34th St	Julia Wilson		Needs a driveway pipe in alley	20' of 12" RCP to be installed
08/17/15	1914 Washington St	Don Potter		Washout area in alley	Street Dept. purposely put a swale in middle of alley at the end because of obstruction on both sides to get the water to drain. Per RM.
08/17/15	3653 Forest Circle	Jill Durham		Asked if whoever was in charge of project in front of house to condiser raising the storm inlet as they did across street	Spoke to workers in field but they were unsure of the plans. Called Josh Webb and left a message, no call back. Spoke to property owner and told her to call JSA and ask for Josh.
08/18/15	539 Woodland Dr	Jan Hunt		Concerned about edge of street eroding away and entrance.	I told property owner the entrance is her responsibility, however we would remove sediment/rock/debris buildup at outlet side of driveway culvert to relieve the culvert of standing water issue. Sent Brandy pictures to see if she wanted to do anything else on the edge of pavement that is eroding away. Brandy said she cannot do any work in there because there is an exposed gas line (see email). RM is doing drainage project in this area and may fix this double barrel under road.
08/21/15	215 Nahm St	Lenny Powley		Does the storm inlet belong to City, maintenance needed	All indications show that this is not a City owned structure in reviewing plat recorded information. The inlet may have been constructed by RR (it seems to be in the RR ROW) or the property owner at one time. See file for email.
08/21/15	4th & Tennessee	Concerned Citizen		Storm inlet missing grate	Directed Pam to create a work request for Streets to replace grate missing from this inlet.
08/21/15	1201 Salem St	Ron White		Believes that the Street Department damaged is property service connection when redoing sidewalk	See property address file to Brandy with pictures. Turned into Martin Russell.
08/25/15	407 Harahan Blvd	Betty Hill		Complaining about her yard with standing issues	Her yard will always have standing water because it is lower than her neighbors and she has a personal gravel drive that keeps it from sheet flowing across the ground creating a dam. We cannot change topography on personal property.
08/25/15	1300 Atkins Ave	Anne Green		Sinkhole next to sidewalk	No storm sewer in the vicinity of the sinkhole. The sanitary sewer lateral connection is near the sinkhole. Directed Anne to call JSA.
08/26/15	721 Bethel Ave	Don Swinford		Drunk driver took out ditches and culverts	Culverts were note damaged, but driveway aprons were. Ditches were fine. Nothing City is responsible for.
08/27/15	3940 Court Ave	Robert Cherry		Storm drain uncovered	Storm drains are mapped and part of system
08/27/15	4137 Minnich Ave	Concerned Citizen		Concerned about the ditch being filled at 4137 Minnich Ave	NOV issued, see address file for letter and pictures
09/02/15	1108 Miller St	Mark Lumbley		Creek in backyard needs to be cleaned	Informed property owner that it was his responsibility, the creek is not located in an easement.
09/02/15	1809 Kentucky Ave	Gary Mercer		Drainage in alley needs to be fixed	Project will be completed in alley at a future date

Citizen Complaint Database

09/03/15	163 Kennedy Rd	Michael Mount	Wants the ditch behind his house dug out and rock added like 205 Kennedy Rd	Left message on the explanation of the work we were doing. Close Out Greg came into the office and spoke to myself and RM. He was told they can fill in low spot with dirt and grade to drain. If wanting to use gravel then they will need to submit a siteplan. The ditch has a couple low spots that are holding water. Regrade ditch for positive drainage, remove high spots and fill in low spots. Spoke to PO. Repair storm inlet, contacted PO
09/09/15	3034 Park Ave	Greg Croft	Wants to fill in low spot on property	Called and emailed Ms. Spry about setting up a meeting with herself, Rick, engineer, and myself Informed property owner to hire contractor to inspect the pipe because it is a driveway entrance pipe (98-31), if it was blocked they would have to clean it. If it was damaged we would perform labor to install.
09/09/15	1102 Markham Ave	Mike Ward	Low spots in ditch	Pipe was not damaged, small amount of sediment build up. Met with PO and told him it was his responsibility to maintain his driveway pipe and entrance. I told him we would not replace the pipe because his current pipe is not damaged.
09/09/15	410 S 22nd St	Dennis Ramage	Reporting unsafe storm inlet	Spoke to Christine Mueller, PO, and she said her landscaper dumped the mulch in the ditch. She will have him bag it and have it ready for refuse.
09/14/15	1241 Elm Dale Rd	Eleanor Spry	Safety issue with ditch in front of school and erosion of road occurring	Spoke to PO and informed them that he would need to dig small portion of ditch out so that the invert of the pipe was exposed in order to use full capacity of pipe and prevent overtopping and erosion.
09/14/15	1625 Bloom Ave	No Name	Driveway pipe caving in	Told property owner that tree would be removed during creek cleaning
09/15/15	118 Nolan Drive	Charles Hayden	Wants pipe replaced, damaged	Told property owner that the City does not like piping long sections of ditch for maintenance purposes. However, if he want to for widening driveway and new entrance to contact me once he removed large tree on private property to widen his driveway.
09/15/15	3429 Central Ave	Andy Shelton	Obstruction in ditch	Spoke to Mark Thompson on 9/23/15 about Parks services spraying and cleaning vegetation out of the creek on City property. I asked Mark if I needed to provide a map or work request, he said no that they were familiar with the section of creek and he would put in a work request for it.
09/15/15	922 Starke Ave	Susan Crouch	Culvert washing out	Remove sediment buildup in ditch to retain capacity. Informed property owner to have the person who maintains her yard to keep it cleaned out on a regular basis to prevent this occurring in the future.
09/15/15	122 Berry Ct	Robert Smith	Dead tree om creek behind property	
09/21/15	309 Vermont St	Jeff Dalton	Wants to pipe ditch	
09/23/15	Brooks Stadium Rd	Several	Cross Creek Cleaning	
09/23/15	3804 Ferncliff Ct	Marsha Cochran	Sediment buildup in ditch	

Citizen Complaint Database

09/24/15	600 Hillgate Rd	Karen Armstrong	Drainage problem in front and wants to get rid of ditch in backyard	Tried calling property owner twice and left messages. If she wants to convey water from ditch to pipe then she will need to hire an engineer to design and submit for approval. The drainage in the front yard is natural downslope and the house is a walkout. If she wants to redirect drainage then this will also need to be designed by an engineer.
09/28/15	3847 Phillips Ave	Concerned Citizen	Drainage ditch has some down trees in it that need to be removed	The City has a drainage esmt for the ditch, ditch was inspected and a few dead trees and small debris were found. Work request sent to Street Department to clean drainage ditch free from obstruction.
10/05/15	935 Oscar Cross Ave	Jay Franklin	Inlet is not flush with curb	This is normal throughout the City of Paducah.
10/08/15	232 N 8th St	Lonnie Turner - Red Crd	Wants to raise parking lot to drain	Directed him that he will need a site plan from a PE to submit to our office. Storm inlet down the street, see pictures.
10/14/15	226 Kennedy Rd	Greg Brown	Pipe for driveway	32" of 12" RCP
10/14/15	2209 S 28th St	Lannie Jones	Pipe for driveway	24" of 12" RCP
10/01/15	246 & 248 Maxfield Dr		Drainage issue and pipe is crushed	Headwall end treatment installed
10/29/15	2620 Jackson St	Tim Grace	Alley drainage issue.	
10/29/15	967 River Oaks Blvd	Lisa Wallace	Need to maintain drainage easement	Ditch along side alley to curb and gutter in S 26th Street Per RM have Central Paving under equipment contract clean from upstream to downstream of concrete ditch
10/29/15	1006 Markham Ave	Kathy Dawes	Standing water issue around garage when it rains	The garage is built lower than the adjacent garage and grade of garage is lower than the 100 year old tree that is in the alley. Nothing we can do with topography on private property.
10/29/15	1634 Bloom Ave	Daniel Thurby	price for pipe for new driveway	16" of 12" RCP and 6 tons of rock = \$282
11/09/15	1920 Seitz Street	Brad Hall	wants to install pipe for wider driveways	Will need 144'
11/09/15	726 N 36th St	Larry Haley	Extending driveway, need pipe	16' of 12" RCP and 2.7 ton of rock \$233.00
11/09/15	728 N 36th St	Larry Haley	Driveway pipe has hole in it, need new pipe	16' of 12" RCP and 2.7 ton of rock \$233.00
11/09/15	1419 Friedman Ln	Trudy Wyatt	Sinkholes developing at top of concrete ditch	Street dept to fill in sinkholes with flowable fill
11/18/15	835 N HC Mathis Dr	Barry	Check drainage on vboth ends of building	Property owner needs to maintain adjoining ROW in a clean and sanitary condition. Once it is mowed we will re-evaluate to see if the ditch needs to be regraded.
11/18/15	3930 Buckner Ln	Jason McHaney	Rip rap falling in ditch, clogged culvert, sinkhole in road	Beat rip rap into bank, clear debris from inlet of culvert, sinkhole needs repair work done
12/01/15	1909 Bridge St	Alvin McCuiston	Alley drainage ditches holding water	South end of alley needs to be re-ditched and driveway pipes cleaned of debris
12/03/15	2639 Clark Street	Scott Hall	Wants to install gravel drive	Directed property owner to keep a swale so as to not obstruct drainage. Does not need a pipe because he would not have enough cover. ROW permit not required per RM
12/07/15	1330 N 14th St	Mrs. Winsett	Alley culvert is clogged with mud	Inspected site, pipe was full of sediment. However, if it is cleaned out it will not improve situation. The downstream grade is built up as a gravel parking area for the Memorial Gardens.

Citizen Complaint Database

12/28/15	830 Davis Ave	Jeanie Embry	Side yard drainage	Cut in a new ditch and remove tree
12/28/15	235 Kennedy Rd	Zoe Nunn	Pipe not draining	Pump truck cleared blockage
12/28/15	Maple & Helen St		flooding	Residents cleared blockage but DS ditch needs cleaning

**B4 - Illicit Discharge and Septic
System Information Sheets**


Please Report Illicit Discharges To The City of Paducah Engineering Department (270)-444-8511

Minimizing Stormwater Pollution Impacts From Your Food Service Establishment


Examples of Illicit discharges:



Always maintain a clean lot. Make sure used cooking oils are not spilled around the oil recycling bin and that bins are serviced/emptied regularly. See that dumpster drain plugs are in place and that food dumpster seals are functioning properly and preventing seepage. Always dispose of mop bucket water down an inside drain, mop sink, or sanitary line and never pour mop water outside onto the lot. Clean up all spills using "Dry" clean-up methods (absorbent material), shovel or scoop up, place in sealed container and dispose of in trash.




Never place oil recycling bins near a garbage dumpster. Bins placed too near a garbage dumpster could be knocked over by the garbage truck during collection.



Never pour fats oils or grease down storm drains, sewer drains, storm grates, or on the ground!



When outside lots or hood vents must be washed/pressure washed, always use proper contain and capture practices and never allow wash water to enter a storm drain even when using biodegradable detergents. The term "biodegradable" simply means that the product will not harm bacteria in the sewage treatment plant and that it breaks down faster than more conventional products. Biodegradable detergents can cause a fish kill in a creek just as fast as any other type of detergent.



Prevent rainwater "inflow" to the Sanitary Sewer. Repair all sewer cleanout covers, cover outdoor mop sinks, and remove gutters that are discharging to any outdoor mop sinks and drains.

KY Transportation Cabinet adapted work by Metro Nashville Stormwater Program.



B5 - JSA Rehabilitation Summary

Cleaning and Video Inspection Totals (linear feet)

173,305

Root Cutting

2,023

Manhole Inspections

542

Rehabilitation Totals

8" Cured-In-Place-Pipe (CIPP) =1,166 ft

10" CIPP = 1,175 ft

12" CIPP = 1,225 ft

15" CIPP = 549 ft

21" CIPP = 410 ft

2 service connection replacements

8 CIPP service connection replacements ("top hats")

Manhole Rehabilitation

30 manholes

**B6 - Illicit Discharge Pictures and
Notice of Violation**



CITY OF PADUCAH

300 South 5th Street

P. O. Box 2267

Paducah, KY 42002-2267

www.paducahky.gov

Phone: (270) 444-8511

Fax: (270) 444-8689

Rick Murphy, P.E.
City Engineer

June 22, 2015

NOTICE OF VIOLATION

James Cleary
2118 South 29th Street
Paducah, KY 42003

VIA: CERTIFIED MAIL

RE: Illicit Discharge at 2118 South 29th Street

Dear Mr. Cleary,

In accordance with the mandates imposed by the Federal Clean Water Act, the City of Paducah was required to establish Ordinances to protect and enhance the water quality of watercourses and water bodies by prohibiting non-storm water discharges and connection to the small municipal separate storm sewer system (MS4).

Evidence exists that you have been dumping cooking oil/grease into the polydrain in front of your residence located at 2118 South 29th Street. Upon investigation, it has been determined that a non-stormwater discharge consisting of cooking grease has been illegally discharged into the storm drain located in front of your residence. This Illicit Discharge is in direct violation of the City of Paducah's Code of Ordinances Chapter 42, Environment:

Sec. 42-52(b) Definition:

"Illicit discharge is any direct or indirect non-stormwater substance or hazardous material disposed, deposited, spilled, poured, injected, seeped, dumped, leaked, or placed by any means, intentionally or unintentionally, into the MS4 or any area that has been determined to drain directly or indirectly into the MS4..."

Sec. 42-52(d)(1) Prohibition of discharges and declaration of nuisance

"No person, company, developer or any other entity shall discharge or cause to be discharged into the MS4 any pollutants including but not limited to hazardous materials or waters containing any pollutants that cause or contribute to a violation of applicable water quality standards, other than stormwater. The commencement, conduct or continuance of any illicit discharge is prohibited."

2118 South 29th Street
June 22, 2015
Page 2 of 2


Therefore, in accordance with Section 42-109, Penalty, James Cleary is hereby fined \$250.00 for the Illicit Discharge of cooking oil into the City of Paducah's MS4.

Sec. 42-109. Penalty:

"The provisions of this article shall be enforced in the same manner as other violations of the this Code. Any person violating any of the provisions of this article shall be deemed guilty of a Class B misdemeanor, and upon conviction thereof, shall receive a fine not to exceed \$250.00 or a jail sentence not to exceed 90 days for each offense. Each day that such violation continues shall constitute a separate offense. This article and the foregoing penalties shall not be construed to limit or deny the right of the city or any person to such equitable legal remedies as may be available by law."

Furthermore, upon receipt of this Notice of Violation, the Illicit Discharge action shall cease immediately. If you have any questions, please call.

Sincerely,



Eric Hickman, P.E.
Storm Water & Drainage Engineer

RM
File





2118 South 29th Street
June 22, 2015
Page 2 of 2


Therefore, in accordance with Section 42-109, Penalty, James Cleary is hereby fined \$250.00 for the Illicit Discharge of cooking oil into the City of Paducah's MS4.

Sec. 42-109. Penalty:

"The provisions of this article shall be enforced in the same manner as other violations of the this Code. Any person violating any of the provisions of this article shall be deemed guilty of a Class B misdemeanor, and upon conviction thereof, shall receive a fine not to exceed \$250.00 or a jail sentence not to exceed 90 days for each offense. Each day that such violation continues shall constitute a separate offense. This article and the foregoing penalties shall not be construed to limit or deny the right of the city or any person to such equitable legal remedies as may be available by law."


Furthermore, upon receipt of this Notice of Violation, the Illicit Discharge action shall cease immediately. If you have any questions, please call.

Sincerely,



Eric Hickman, P.E.
Storm Water & Drainage Engineer

RM
File



A US Bank check with a palm tree watermark. The check is dated 2/24/16 and is payable to the City of Paducah for \$250.00. The check number is 1252. The payee is Shaketha B. Cleary. The check includes the US Bank logo and the slogan "Every cloud has a silver lining".

JAMES D. CLEARY
SHAKETHA B. CLEARY
2118 S. 29TH ST.
PADUCAH, KY 42003-3606

78-38/838 1252
Date 2/24/16

Pay to the order of City of Paducah \$ 250.00
Two hundred fifty + 00/100 Dollars

Every cloud has a silver lining

usbank. All of us serving you

Memo Violation Fine Illicit Discharge Shaketha B. Cleary NP


⑆083900363⑆ 145808224037⑆ 1252

DESERT PALMS

**B7 - Illicit Discharge Inspection
Pictures/Maps/Data**

OBJECT ID
21418

09/24/2015



OBJECT ID 538



09/24/2015



OBJECT ID

464

09/23/2015



OBJECT ID
466

09/23/2015

09/23/2015



7

OBJECT ID
467

09/23/2015





ID = 467

PAGE 1
ID = 466

ID = 464

S 24TH ST

SEITZ ST

MISSISSIPPI ST

VIRGINIA ST

CENTER ST

S 28TH ST

CORNELL ST

ALABAMA ST

Cross Creek

2364
2337
2331
2327
2323
2338
2320
2322
2306
2310
2640
2337
2333
2329
2317
2315
2306
2310
2336
2324
2328
2316
2305
2301
2332
2325
2321
2317
2313
2307
2301
2340
2340
2310
2302
2300
2806
2810
2810
2810
2823

2337
2331
2327
2323
2338
2320
2322
2306
2310
2600
2226
2222
2200
2237
2229
2225
2221
2219
2209
2232
2222
2205
2201
2218
2214
2204
2200
2239
2235
2231
2217
2215
2205
2201
2209
2200

2300
2600
2226
2222
2200
2237
2229
2225
2221
2219
2209
2232
2222
2205
2201
2218
2214
2204
2200
2239
2235
2231
2217
2215
2205
2201
2209
2200

2142
2130
2120
2112
2100
2141
2135
2127
2123
2136
2134
2128
2116
2106
2139
2129
2119
2109
2105
2101

2142
2130
2120
2112
2100
2141
2135
2127
2123
2136
2134
2128
2116
2106
2139
2129
2119
2109
2105
2101

2027
2036
2017
2018
2010
2006
2043
2037
2027
2046
2038
2032
2024
2016
2006

2529
2537
2543
2549
2010
2006
2043
2037
2027
2046
2038
2032
2024
2016
2006

OBJECT ID 314

09/22/2015



64 x 42 CM Arch
① ②
9/22/15



3955

3950

4001

PHILLIPS AVE

823

MYER

② ID=314

809

3941

3951

PRIMROSE PL

3944


3954

4015

4020

OBJECT ID
302

00/99/2015



255

539

BROOKFIELD DR

250

243

520

529

234

② 36x31 Elliptical CMP
ID 362

510

230

WOODLAND DR

515

217

511

215

IDLEWILD DR

216

502

214

500

202

501


OBJECT ID
453

09/22/2015

SSB 0114

OBJECT ID
454

09/22/2015





115

118

DEER PATH LN

101

100

217

201

175

233

193

200

192

190

185

DOVE LN

QUAL HOLLOW RD

RED FOX TRL

4568

4556

4545

4548

4531

4536

ID=34

ID=453

31x43
elliptical
CMO
No

4

OBJECT ID 381

09/22/2015



OBJECT
ID 550

11/09/22/2015

m



OBJECT ID 241

09/24/2015





OBJECT ID
383

09/23/2015



705 705 711 715 715 723 723 723 723 723 723 719 719 719 719 719 2309 2309 2307 2307 2307 2307 2305 2305 2305 2305 2303 2303 2303 2301 2301 2301 2301 2301 2250 2200 2200 2200 2300 2401 2400 801 805 813 820 828 2012 900 901 911 916 920 926 930 917 917 1000 1006 1016 1020 1023 1024 903 905 900 909 910 930 1001 1000 1001 1008 1010 1014 1016 1018 1020 1026 1028 1103 1103 1104 1105 1114 1114 1120 1107 1107 1120 1109 1109 1122 1117 1108 1105 1010 1010 1020 1025 1099 1101 1102 1101 1/2 1104 1104 1106 1106 1108 1008 1010 1014 1016 1018 1020 1026 1028 1102 1101 1104 1103 1105 1108

OBJECTID	Element_Type	HDWL_Ma	Pipe_Type	Pipe_Size	Screening_Date	MS4_Outlet	Illicit_Discharge	Source_Found	Source_Address	NOV_Issued	Remediation_M	Clogged_Debris	Flow_Performance	Invert_Elev	Rip_Rap	Erosion_Present	Condition	Condition_Text	Comment	Last_Edited_By	Last_Edited_On	last_edited_user
441	Pipe	<Null>	Vitrified Clay Pipe	36	9/24/2015	Yes	No	<Null>	<Null>	<Null>	<Null>	Yes	Poor	<Null>	No	Severe	Poor	Outlet 75% full of water	<Null>	EH_2015	9/24/2015	EHICKMAN
538	Headwall	Concrete	Reinforced Concrete Pipe	36	9/24/2015	Yes	No	<Null>	<Null>	No	<Null>	Yes	Limited	<Null>	Yes	None	Poor	<Null>	Standing water at outlet	EH_2015	9/24/2015	EHICKMAN
21418	Headwall	Concrete	Reinforced Concrete Box Culvert	144	9/24/2015	Yes	No	<Null>	<Null>	No	<Null>	Yes	Good	<Null>	No	None	Good	Lots of debris	120x144 Rect	EH_2015	9/24/2015	EHICKMAN
62	Pipe	<Null>	Vitrified Clay Pipe	15	9/23/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	Yes	Slight	Good	<Null>	<Null>	EH_2015	9/23/2015	EHICKMAN
464	Headwall	Concrete	Concrete	36	9/23/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	None	Excellent	<Null>	Concrete Ditch	EH_2015	9/23/2015	EHICKMAN
466	Headwall	Concrete	Reinforced Concrete Pipe	48	9/23/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	Yes	None	Good	Vegetation growth	<Null>	EH_2015	9/23/2015	EHICKMAN
467	Headwall	Concrete	Concrete	36	9/23/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	None	Excellent	<Null>	<Null>	EH_2015	9/23/2015	EHICKMAN
314	Headwall	Concrete	Corrugated Metal Pipe	66	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	Yes	Slight	Excellent	small amount of debris	64x43 elipt	EH_2015	9/22/2015	EHICKMAN
362	Pipe	Steel	Corrugated Steel Pipe	36	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	None	Good	Vegetation at outlet	Private Pipe	EH_2015	9/22/2015	EHICKMAN
381	Headwall	Concrete	Corrugated Metal Pipe	114	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	None	Good	Algae present	Private System	EH_2015	9/22/2015	EHICKMAN
453	Pipe	Other	Corrugated Metal Pipe	36	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	Slight	Good	Invert dropoff	Private Pipe	EH_2015	9/22/2015	EHICKMAN
454	Pipe	Other	Corrugated Metal Pipe	36	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	Slight	Good	Invert dropoff	Private Pipe	EH_2015	9/22/2015	EHICKMAN
550	Headwall	Concrete	Concrete	48	9/22/2015	Yes	No	<Null>	<Null>	No	<Null>	No	Good	<Null>	No	None	Good	Vegetation at outlet	<Null>	EH_2015	9/22/2015	EHICKMAN
383	Pipe	Concrete	Reinforced Concrete Pipe	36	9/23/2015	Yes	No	<Null>	<Null>	<Null>	<Null>	<Null>	Limited	<Null>	No	None	<Null>	holding water	<Null>	EH_2015	9/23/2015	EHICKMAN